



Rapid Entry System KNOX-BOX®



The Shelby Township Fire Department requires a locking KNOX key box on all commercial buildings as defined by the Fire Code Official, or where immediate access is necessary for life-saving or fire fighting purposes per the 2009 International Fire Protection District, Section 506.1 as Amended.

LOCATION: The KNOX key box shall be located within ten (10) feet of the “main entry door” of the building and between five (5) and six (6) feet above the finished grade.



Multi-Tenant Buildings – Contact the Shelby Township Fire Department Inspection Division for placement.

DECALS: The KNOX decal shall be installed at the main front entrance or as required by the Fire Code Official.

BUILDING KEYS: The box shall contain labeled keys, including but not limited to: keys for access into and through the premises, keys to any secured fire protection system, and elevator keys.

MAINTENANCE: The Operator of the building shall immediately notify the Fire Code Official and provide new keys when a lock is changed or rekeyed.

ORDERING: You can now order KNOX equipment on-line from the KNOX Company homepage at: www.knoxbox.com. Search by zip code “48316” or department “Shelby”, and then choose “Charter Twp of Shelby.” Applications are also available at Shelby Fire Headquarters, Station 1.

RECOMMENDED PRODUCTS:

PRODUCT	MODEL	SPECIAL INFORMATION
Surface Mount Box – w/Hinged Door	3200 Series	No Tamper Switch Required
Recessed Mount Box – w/Hinged Door	3200 Series	No Tamper Switch Required

Shelby Township Fire Department
Headquarters – 6345 23 Mile Road - Shelby Township, MI 48316
586.731.3476
www.shelbytwfd.com